

Diámetro Interior y Perdida de Carga

Tramos rectos de tuberías, Válvulas y Accesorios



1 Datos del Proyecto y del líquido:

2	Servicio = Descarga Bomba Centrífuga (Agua)	
3	P [bar] = Presión de diseño de la línea	45
4	Q [m ³ /h] = Caudal de operación	150
5	v [m/s] = Velocidad de proyecto	2,50
6	v [m/s] = Velocidad real en la tubería	2,48
7	T [°C] = Temperatura de Operación	100
8	ρ [kg/m ³] = Densidad del fluido	960,0
9	μ [kg/ms] = Viscosidad Dinámica @ temperatura de trabajo	0,0002829
10	ν [m ² /s] = Viscosidad Cinemática @ temperatura de trabajo	0,0000003

11 Datos de la tubería:

12	Material = Metalurgia de la tubería para determinar la rugosidad	Acero comercial
13	NPS [in] = Nominal Pipe Size tubería	6
14	De [mm] = Diámetro exterior	168,3
15	SCH [adim] = Schedule	80
16	D [mm] = Diámetro interior	146,36
17	L [m] = Longitud del tramo recto	475
18	ϵ [mm] = Rugosidad absoluta tubería limpia	0,0500

19 Pérdida de Carga Total del sistema

20	hf [mcl] = Pérdida de carga total del sistema	=	26,024
21	hf [bar] =	=	2,549

22 Pérdida de Carga en tramos rectos de tubería:

23	hft [mcl] = $f \cdot L \cdot v^2 / D \cdot 2g$ pérdida de carga en tramo recto de tubería (Darcy-Weisbach)	=	16,224
24	htf [bar] =	=	1,589
25	Re [adim] = $D \cdot \rho \cdot v / \mu \rightarrow D \cdot v / \nu$ Número de Reynolds	=	1.230.027
26	f [adim] = $64/Re$ flujo laminar $\rightarrow RE < 2000$ (Poiseuille)	=	NA
27	f [adim] = Churchill 1977, reproduce Moody en todos los regímenes	=	0,0160
28	f [adim] = Cheng 1979, buena performance para régimen turbulento \rightarrow solo para referencia	=	0,0159

29 Pérdida de Carga en fittings, válvulas y otros

30	hff [mcl] = Pérdida de carga total en Fittings (mcl)	=	9,800
31	hff [bar] =	=	0,960
32	f [adim] = Crane, tubería de acero comercial, flujo totalmente turbulento \rightarrow para válvulas y fittings	=	0,015

Se calcula la pérdida de carga mediante las ecuaciones más usadas de acuerdo a las buenas prácticas de ingeniería

Se calcula la pérdida de carga según las ecuaciones del método analítico de Crane.

Esta hoja ha sido desarrollada solo para fines educativos, usar bajo su propia responsabilidad.



Piping Flexibility Analysis

Design Code: ASME B31.1


Case 6. Calculation of Reaction Force in support

Design Conditions

21	Ta [°C] - Ambient Temperature
70	Ta [°F] - Ambient Temperature
390	Td [°C] - Design Temperature
734	Td [°F] - Design Temperature
35000	N [dless] - Total number of thermal cycles

Dimensions:

8	NPS [in] - nominal pipe size
8.625	Do [in] - pipe outside diameter
40	SCH [dless] - schedule of the pipe
6	D [m] - Distance subjected to thermal growth
0	ΔL ₁ [in] - Initial displacement of left end
1.5	ΔL ₂ [in] - Initial displacement of right end



Material and Conditions:

A-335 P5	Material	(5 Cr)
17.1	Sc [Ksi] - allowable stress @ ambient conditions	
15.1	Sh [Ksi] - allowable stress @ design conditions	
31,000	E [Ksi] - Moduli of Elasticity @ ambient (Table C-1)	
6.40	Exp [in/100 ft] - Total expansion coeficient (Table B-1)	
0.7	f [dless] - Stress Range Factor (fig.102.3.2)	
16.81	Z [in3] - section modulus	

Preliminary calc's:

23	ΔL_3 [in] = L * Exp	Total movement of pipeline due to expansion	= 1.28	32.53
24	ΔL [in / mm] = ΔL ₁ + ΔL ₂ + ΔL ₃	Total movement of the pipeline due to expansion	= 2.78	70.6
25	SA [Ksi] = f*(1,25*Sc + 0,25*Sh)	allowable displacement stress range	= 19	

Cantilever method: Arm to absorb expansion

27	L [ft] = (3*E*Do*ΔL)/144*SA) ^{0,5}	minimum required arm	= 28.85	8.79
----	---	----------------------	---------	------

Flector moment at fixed support

29	M [lb-ft / Nm] = P*L / 2 -> S = M / z	flector moment at fixed support	= 26076	34971
----	---------------------------------------	---------------------------------	---------	-------

Load at fixed support

31	P [lb / N] = SA*2*z / L	load at fixed support	= 1808	7955
----	-------------------------	-----------------------	--------	------


This sheet provides a simplified method to establish the number of loops for a given shape
 This sheet can only deliver conservative results. For a more accurate design, please use flexibility software.
 This sheet will not calculate biplanar systems
 This sheet is for educational use only - use at your own risk.

MAXIMUM SPACING BETWEEN SUPPORTS FOR SPECIAL CONFIGURATIONS

Select the appropriate configuration of your pipeline from the options below and the design conditions entered above will be corrected for the special configuration selected. Find corrected values for the chosen option below.


Direction change in the same plane:

$$L' = 0,75L$$




Direction Change in two planes:

$$L' = 0,65L$$



Branches:

$$L' = 0,70L$$




Concentrated loads (valves, fittings)

$$L' = CL' (+)$$

Data:

P	2000
a/L'	0.50

[kg]



- a : distance from load to nearest support
- P : weight of the Concentrated load
- W : Pipe+fluid+insulation weight by length unit
- L : support spacing for straight runs
- L' : corrected spacing considering concentrated load

Where:

$$\alpha = a / L'$$

$$\beta = P / WL$$

$$C = -6\alpha\beta(1-\alpha)^2 + \sqrt{1 + [6\alpha\beta(1-\alpha)^2]^2}$$

Correction Factors

Support Spacing Special Configuration

	Empty	Empty, Insulated	Fluid	Fluid + Insulation
L'	6186	6078	5812	5733
L'	4137	4065	3887	3834
				Selected configuration
				Free End (last spacing)